

2024 Water Quality Report for Chassell Township

Water Supply Serial Number: 1350

This report covers the drinking water quality for Chassell Township for the 2024 calendar year. This information is a snapshot of the quality of water that we provided to you in 2024. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (USEPA) and state standards.

Your water comes from 9 groundwater wells, each over 180 feet in depth. The new source wells went active in October of 2004. Water is pumped from these wells to the chlorination plant. These are located west of town. The State performed an assessment of our source water in 2003 to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is Moderately High.

Contaminants and their presence in water: Drinking water, including bottled water, may be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by call the USEPA's Safe Drinking Water Hotline (800-426-4791).

Vulnerability of sub-populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Center for Disease Control guidelines on

appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Sources of drinking water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

To ensure that tap water is safe to drink, the USEPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled

water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2024 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2024. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- N/A: Not applicable
- ND: not detectable at testing limit
- ppm: parts per million or milligrams per liter
- ppb: parts per billion or micrograms per liter
- pCi/l: picocuries per liter (a measure of radioactivity)
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Information about lead:

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Chassell Township is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water and wish to have your water tested, contact Chassell Township at 906-481-4000 for

available resources. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Monitoring Data for Regulated Contaminants

| Regulated Contaminant | MCL, or MRDL | MCLG, or MRDLG | Level Detected | Year Sampled | Violation Yes/ No | Typical Source of Contaminant |
|----------------------------------|--------------|----------------|----------------|--------------|-------------------|--|
| Arsenic (ppb) | 10 | 0 | ND | 2019 | No | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes. |
| Barium (ppm) | 2 | 2 | .0032 | 2019 | No | Discharge of drilling wastes; Discharge of refineries; Erosion of natural deposits. |
| Nitrate (ppm) | 10 | 10 | 0.19 | 2024 | No | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Fluoride (ppm) | 4 | 4 | .10 | 2023 | No | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Sodium (ppm) | N/A | N/A | 2.4 | 2023 | No | Erosion of natural deposits. |
| TTHM Total Trihalomethanes (ppb) | 80 | N/A | 4.71 | 2024 | No | Byproduct of drinking water disinfection. |
| HAA5 Haloacetic Acids (ppb) | 60 | N/A | 1.1 | 2024 | No | Byproduct of drinking water disinfection. |
| Chlorine (ppm) | 4 | 4 | 0.44 | Monthly | No | Water additive used to control microbes. |
| Alpha Emitters (pCi/L) | 15 | 0 | 9.19 | 2024 | No | Erosion of natural deposits. |
| Combined Radium (pCi/L) | 5 | 0 | 1.29 | 2024 | No | Erosion of natural deposits. |

- Sodium is not a regulated contaminant.
- The chlorine "Level Detected" was calculated using a running annual average.

| Inorganic Contaminant Subject to AL's | AL | MCLG | Your Water | Range of Results | Year Sampled | Number of Samples above AL | Typical Source of Contaminant |
|---------------------------------------|----|------|------------|------------------|--------------|----------------------------|-------------------------------|
| | | | | | | | |

| | | | | | | | |
|--------------|-----|-----|-----|---------|------|---|---|
| Lead (ppb) | 15 | 0 | 1 | 0-3 | 2023 | 0 | Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits. |
| Copper (ppm) | 1.3 | 1.3 | 0.6 | 0.1-0.8 | 2023 | 0 | Corrosion of household plumbing systems; Erosion of natural deposits. |

- Ninety (90) percent of the samples collected were at or below the level reported for your water.

Monitoring and Reporting to the Michigan Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the USEPA require us to evaluate our water on a regular basis to ensure its safety.

Violations for 2024

We received a Monitoring Violation for failing to collect the required Bacteriological samples in December 2024. We returned to compliance with collection of our January bacteriological samples on January 6, 2025.

We will update this report annually and will keep you informed of any problems that may occur throughout the year as they happen. This report will not be mailed to customers. Copies are available at the Township office during regular office hours. For more information about your water or the contents of this report, contact:

Craig Austin, Chassell Township, P.O. Box 438, 22115 7th St., Chassell, MI 49916, (906) 481-4000

We invite public participation in decisions that affect drinking water quality. Chassell Township Board Meetings are regularly held the second Wednesday of every month at 6:00 PM EST at the Chassell Township Fire Hall.

For more information about safe drinking water, visit the USEPA at <http://www.epa.gov/safewater>.